



Certificate of Compliance

Certificate: 70147967 (LR 105629-1)

Master Contract: 185724

Project: 70157648

Date Issued: 2017-09-28

Issued to: Engeser GmbH Kabeltechnik
Angelwasenstrasse 27
Waldmossingen
Schramberg, 78713
GERMANY
Attention: Christian Schmodde

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Michael Chung
Issued by: Michael Chung

PRODUCTS

CLASS 6223 81 - WIRE CONNECTING DEVICES – Bare and Covered Ferrules-Cert. to US Stds.
CLASS 6223 01 - WIRE CONNECTING DEVICES – Bare and Covered Ferrules

Insulated ferrules, Series E100, E200, E300, Z100, Z200, Z300; non-insulated ferrules Series U100, U200, U300, for use with Nos 4/0-26 AWG stranded copper wires.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 291-14, 1st Ed - Bare and covered ferrules
UL Std. 486F, 1st Ed - Bare and covered ferrules



Supplement to Certificate of Compliance

Certificate: 70147967 (LR 105629-1)

Master Contract: 185724

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70157648	2017-09-28	Add non-insulated ferrules Series U100, U200, U300.
70147967	2017-08-24	Compliance with CSA Std. No 291-14
-1	1995-05-16	Original Certification Series E100, E200, E300, Z100, Z200, Z300.